


# ওয়েষ্ট বেঙ্গল গ্রামীণ ব্যাঙ্ক

(সরকারী মালিকানাধীন শিডিউল্ড ব্যাঙ্ক)  
মোরাপোড়া চৌপাঠী, দিনহাটা রোড  
পোঃ কোচবিহার, জেলা - কোচবিহার  
পশ্চিমবঙ্গ - ৭৩৬১০১, ভারত  
ওয়েবসাইট: <http://www.wbgb.co.in>



## West Bengal Gramin Bank

(Scheduled Bank Owned by Government)  
Morapora Chowpathi, Dinhata Road  
Po: Coochbehar, Dist.- Coochbehar  
West Bengal 736101, India  
Website: <http://www.wbgb.co.in>

Date: 28.11.2025

### TENDER INVITATION

Sealed tenders are invited by Regional Office-West Bengal Gramin Bank, Dinhata Road, Morapora Chowpathi, Coochbehar - 736101, West Bengal for its Kuchlibari Branch to execute composite work which includes ELECTRICAL work under (Two) bid System i.e. Technical Bid (Cover-I) & Price Bid (Cover-II).

**Name of Work:** ELECTRICAL works of **KUCHLIBARI BRANCH** of West Bengal Gramin Bank.

**Cost of Tender Document:** ₹500/- (Rupees Five Hundred Only) to be paid by demand draft or Banker's Cheque favoring West Bengal Gramin Bank, Regional Office- Coochbehar, Payable at Coochbehar.  
**(Non Refundable)**

**Availability of Tender Documents:** West Bengal Gramin Bank,  
Regional Office  
Dinhata Road, Morapora Chowpathi,  
Coochbehar-736101,  
West Bengal  
OR  
[wbgb.co.in](http://wbgb.co.in)

**Issue of the Tender Documents:** From 28.11.2025 to 15.12.2025 between 10:00 Hrs. to 15:30 Hours, Except Sundays and Holidays.

**Time & date of Submission of Tender:** Up to 3:00 P.M. on 28.11.2025

**Time and Date of Opening of Tender** 12:30 P.M. on 15.12.2025

**Venue of the Tender opening:** West Bengal Gramin Bank  
Regional Office, Dinhata Road, Morapora Chowpathi,  
Coochbehar-736101, West Bengal

**Tender to be addressed to:** To,  
The Regional Manager  
West Bengal Gramin Bank  
Regional Office  
Dinhata Road, Morapora Chowpathi,  
Coochbehar-736101,  
West Bengal

For and on behalf of  
WEST BENGAL GRAMIN BANK  
Regional Manager  
Regional Office, Coochbehar

**ENVELOPE-2: Price Bid (MARKED AS ENVELOPE II)**

This ENVELOPE shall contain the following

Envelope Marked II shall contain the Price Bid submitted on the printed Forms issued by the bank. The tenderer shall quote the final amount in both figure and words.

**Terms & Conditions:**

1. Quotation will be considered on lower rate ( LI) basis.
2. After expiry of scheduled time frame no quotation will be accepted.
3. Bank authority reserves the right to accept or cancel bid unilaterally without assigning any reason thereof prior to the placement or supply order/signing contract thereby.
4. Delay or deviation in work material or time may attract penalty on bill amount.
5. GST no. is mandatory to submit quotation.
6. Rates will be inclusive all charges except GST.
7. Tenderers are advised to visit the branch site to assess the scope of work.
8. Uncompromising adherence to material and workmanship quality standards is required.
9. Vendors should preferably have an established office unit in North Bengal.

For and on behalf of  
WEST BENGAL GRAMIN BANK  
*MS*  
Regional Manager  
Regional Office, Cooch Behar

For and on behalf of  
WEST BENGAL GRAMIN BANK  
*Satyam Kumar*  
Manager  
Regional Office, Cooch Behar

## Electrical Work Of WBGB Kuchlibari Branch, Coochbehar

SLNo.	Description	Quantity/area	Rate	Amount
<b>1.</b>	<b>COMPUTER DATA SYSTEM/LAN WIRING</b>			
a.	Supplying and laying of CAT-6 cable through suitable size PVC casing capping from server to HUB,HUB to Computer Data Socket including interconnection mending good etc. as required (Make - Havells / Finolex / Polycab/ KEI)	6 nos.		
b.	Supply and fixing on wall/furniture/partition recessed non-modular type Computer data socket (D-Link make) with mounting box & front plate as shown in the drawing complete with mending good etc. as required. (Make - L&T / Anchor-Panasonic/ Crabtree/ Legrand) ( For BM-2 points)	6 each		
<b>2.</b>	<b>MAIN LINE WIRING</b>			
a.	Supply and laying 2x6sqmm+1x4sqmm PVC insulated copper wire from Panel board to CDB (Make - Havells / Finolex / Polycab/ KEI)	15 mtr		
b.	Supply and laying 2x4sqmm+1x2.5sqmm PVC insulated copper wire from TPN MCB DB to power plug (Make - Havells / Finolex / Polycab/ KEI)	60 mtr.		
<b>3.</b>	<b>RAW POINT WIRING</b>			
a.	Supply and laying 2x6sqmm+1x4sqmm PVC insulated copper wire (MCB DB TO RAW POINT ) (Make - Havells/ Finolex/ Polycab/ KEI)	65 mtrs.		
<b>4.</b>	<b>UPS WIRING</b>	<b>2 set</b>		
a.	Supply fixing & connection of UPS circuit line with 1.1kv grade PVC insulated non sheathed stranded copper cable of (FRLS) with 2x2.5sqmm+1x1.5sqmm through rigid PVC conduit 20 mmdia 1.6mm wall thickness, with ISI marks, to lay from UPS MCB DB to plug point board. Two nos point to be connected from One circuit. (Make - Havells /Finolex/ Polycab/ KEI)	75 mtr		
b.	Supply,fabrication & fixing of computer board made of 2 nos 5 pin 6 A modular socket & 1 No. 5 pin 16 A socket along with 6A & 16A individual switches having fixed with 1 No.LED indicator and 1 No. board fuse on suitable size GI switch board connection & recessed in wall with mending good all damages as per direction of EIC. (Make - L&T / Anchor-Panasonic/ Crabtree/ Legrand)	5 sets		
c.	Supply,installation,testing & commissioning of Legrand make 32A-3pin wall mounted,industrial type metal clad socket with plug top & 32A SPN MCB control (For UPS Room) (Make - L&T / Anchor-Panasonic/ Crabtree)	4 nos.		
d.	Supply laying & connection of UPS incoming power line with 2x10mmsq+1x6mmsq PVC insulated stranded copper wire from PANEL BOARD to UPS incoming power switch. (Make - Havells / Finolex / Polycab/ KEI)	30 mtr		
<b>5.</b>	<b>EARTHING</b>			

a.	Earthing with Copper plate (610x610x3mm size) having weight of 9.84 Kg and 1 No. 25x5mm Copper strip (3.20 mt long) & 1 no. 6 sqmm PVC insulated stranded Copper wire (4 Mt long) incl. S & F 15 mm dia GI pipe (ISI-Medium) protection (4 mt. long) to be filled with bitumen, partly under the ground level & partly above ground level to an average depth of 3.65 Mts. below the ground level and restoring the surface duly rammed incl. providing 3.0 mt long, 25 mm dia GI pipe (ISI-Medium) for periodic treatment, incl. providing masonry enclosure on the top of the earth electrode of overall size 86.36x86.36x46cm deep (below Ground level) complete with cemented brick work (1:6) of 25 cm width, duly plastered with cement mortar (inside) CI hinged inspection cover of size 36.56x35.56cm with locking arrangement, GI reducer and treatment of soil by using salt & charcoal or coke for plate electrode. (1 No. For Main Panel & 1 No. For UPS)	2 nos.		
b.	Providing and fixing Copper Earth Wire 8 guage in pvc conduit in Floor / walls From earth pit to earthing station & finally connected to Main Panel Board Complete.	70 mtr.		
c.	Providing and fixing Pipe Earthing (IS 3043 Code) 3.0m. deep with 40 mm. dia. GI pipe With perforations filled with alternate layers of Charcoal and salt. The item includes Funnel on top in brick masonry chamber with CI cover for watering purpose complete.	2 set		
6.	<b>MAIN ELECTRICAL CUBICAL PANEL</b>	6 nos.		
a.	Floor/wall mounting type . Supply, fabricating, assembling, interconnection,testing,&connecting with incoming,out going power cables & lines as required to complete the job of cubical type electrical panel made from 14SWG CRC sheet with proper earthing terminal(nut,bolt and washer) 2 no. outside panel, same nult,bolt to tighten with internal earth busbar of panel situated inside wire box(on top portion of panel).On top side of panel cable entry arrangement to be done for incoming and out going of lines.Painting powder coating electrical grey/siemens grey to be done.One 6"x4" 440V danger board to fix up on main panel busbar cover.All switches are front handle operated & all MCB knob should be visual,all components should provide in separate compartments only.One DB and one busbar(main incoming for ac and panel board and for panel board alone ) in one compartment.All door are detachable type with IP protection.	6 nos.		
	i) 500 V 100 A TPN HRC fuse-1			
	ii) 500V 63A TPN HRC fuse - 1			
	iii) 500V 63A TPN on Load change over switch - 1			
	iv) 500V 100 A bus bar Cu with BBC on heavy duty porcelain chairs - 2 set			
	v) 500 V 63 A FP MCB-2NO.			
	vi) 230V/415 V 40A(10KA) SP MCB-4No.			
	vii) 230V/415V 25A (10 KA) SP MCB-1 and HAVELLS XPRO (glow sign board )			
	viii) 0-100 Amp. Ammeter with selector switch- 1 Set			
	ix) 0-500V Voltmeter with selector switch - 1 set			

	x) 100/5 CT - 3 Nos			
	xi) LED Indicator lamp - 3 Nos			
	xii) Medium pressure caution Board - 1 No.	1 set.		
6.	<b>Main Incoming Switch Fuse Unit.</b> Supply fixing of 100 Amps TPN HRC type SFU at WBSEB end for main incoming on MS angle. Frame & 02 nos Cable end box including connection.	1 set		
7.	<b>COMPUTER DISTRIBUTION BOARD</b>			
a.	Supply & installation of following HAVELLS/ LEGRAND make 12 way TPN MCB distribution board with MCB having short circuit breaking capacity of 10KA or RCBO of 100 mA sensitivity having overload short circuit & earth leakage protection complete with neutral, phase & earth bar with 1 No. 40A DP RCBO as incoming 8x6A SPMCB as outgoing to be partially recessed in wall.	35 mtrs		
8.	Supply of CAT-6, 24 Port Patch Panel of GD Sole/DLink Make	1 nos.		
9.	Supply of 9U. Metal Rack with Glass door.	1 nos.		
10.	Supply of CAT-VI 1 Mtr. Patch Cord	6 Nos.		
11.	Supply of CAT-VI 2 Mtr. Patch Cord	6 Nos.		
12.	Installation with crimping of of CAT-6, 24 Port Patch Panel of GD Sole/D-Link Make	1 no.		
13.	Installation with fixing of of 9U. Metal Rack with Glass door.	1 no.		
14.	Supply & installing of 32A DP MCB with suitable size metal box complete (for Lighting Cutoff switch near bank entry/exit gate) for 2 nos. LDB CUTT OFF control. (Legrand make)	1 set		
15.	Supply & installing of 63A 4 pole MCB with suitable size metal enclosure for UPS main control near UPS	1 set		

**Total Amount (Inclusive all charges & With Out GST) =**

**GST No:**

**Signature with Seal.**